

ANNUAL DRINKING WATER REPORT 2013-2014

ST. JOSEPH'S CATHOLIC SCHOOL, CALABOGIE

Introduction

The Renfrew County Catholic District School Board is pleased to present to the parents and students of St. Joseph's, Calabogie its annual drinking water report. The province's Drinking Water Protection Regulation for Smaller Water Works Serving Designated Facilities requires that we publish this report for your information. Here you will find the water quality and other information that we were required to collect for the annual period April 1, 2013 to March 31, 2014.

If you have a question about the St. Joseph's, Calabogie water supply or this report, please call the Community Use of Schools/Plant Services Officer @ 613-732-8534, or school principal Rory Donahue @ 613-752-2808 during business hours.

Water System Information

St. Joseph's has been served by an on-site well supply inside the building since the school was built in 1931. The well was drilled when the expansion was built in 1969 to a depth of approximately 16 meters, where water is obtained from clay over gravel aquifer. In order to comply with the minimum treatment requirements contained in the regulation, ultraviolet disinfection equipment was installed in the spring of 2002. A professional engineer hired by the Board provided certification that the water works at the school meets the minimum requirements set forth in the regulation. This engineering assessment and certification is a mandatory requirement of the regulation.

Equipment Costs Incurred in 2013-2014

The cost of treatment equipment, weekly testing and the consultant was approximately \$4216.60

Summary of notices and reports

As required by the regulation, the Renfrew County Catholic District School Board submitted a notice to the Ministry of the Environment and to the interested authority (the Ministry of Education) advising it that the water supply at the school did not meet the minimum treatment requirements. The notice of non-compliance also advised that the Board had retained the services of an engineering consultant and planned to be in compliance by March 2002.

In March 2002, after the new water works commenced operation, the Board submitted its engineer's report to the Ministry of the Environment and the interested authority (the Ministry of Education) as required by the regulation. In October 2012 a new engineers report was required. This report was submitted to the Ministry of the Environment and the interested authority (The Ministry of Education) as required by the regulation. Both reports certified that St. Joseph's School, Calabogie water works met all requirements.

On October 3, 2012 a Ministry of the Environment Drinking Water Inspection was completed. ACTION Required items were to have immediate update of the registration profile and to provide a new EER report. All information in this report can be viewed online or at the request of an individual at St. Joseph's Catholic School.

RENFREW COUNTY CATHOLIC DISTRICT SCHOOL BOARD

Adverse water quality notifications and corrective actions

There were no notices submitted to the Ministry of the Environment and the local Medical Officer of Health indicating samples with adverse water quality as no adverse readings were found.

Summary of water quality

The regulation requires the Board to sample for various types of water quality parameters at prescribed frequencies. The results are presented below, followed by some definitions you may find useful.

***Summary of Results for Microbiological Parameters
April 1, 2013- March 31, 2014***

Parameter	Sample Type	Frequency	# of samples Yearly	Amount Detected	# of exceedances
Total Coliforms (per 100 mL)	Raw Water	Monthly	12	1	N/A
Total Coliforms (per 100 mL)	Treated Water	Monthly	12	ND	0
Total Coliforms (per 100 mL)	Distribution Line	Monthly	12	ND	0
E.coli (per 100 mL)	Raw Water	Monthly	12	ND	0
E.coli (per 100 mL)	Treated Water	Monthly	12	ND	0
E.coli (per 100 mL)	Distribution Line	Monthly	12	ND	0
Nitrites/Nitrates (N)	Treated	Quarterly	4	4.9 mg/L 4.3 mg/L 2.7 mg/L 1.7 mg/L	0

***ND – non detectable**

RENFREW COUNTY CATHOLIC DISTRICT SCHOOL BOARD

*Summary of Results for Chemical Parameters
(Collected May 22, 2012)*

Parameter	M.D.L	Pump Room Treated	Kitchen/Staff Room
Antimony	0.0001	0.0001	--
Arsenic	0.0001	0.0001	--
Barium	0.001	0.002	--
Boron	0.005	0.027	--
Cadmium	0.00002	<0.00002	--
Chromium	0.002	<0.002	--
Lead	0.00002	--	0.00382
Mercury	0.00002	<0.00002	--
Selenium	0.001	<0.001	--
Sodium	0.2	199	--
Uranium	0.00005	0.00061	--
Benzene	0.5	<0.5	--
Carbon Tetrachloride	0.2	<0.2	--
Dichlorobenzene 1, 2-	0.1	<0.1	--
Dichlorobenzene 1, 4-	0.2	<0.2	--
Dichloroethane 1, 2-	0.1	<0.1	--
Dichloroethene 1, 1-	0.1	<0.1	--
Dichloromethane (Methylene Chloride)	0.3	<0.3	--
Monochlorobenzene (Chlorobenzene)	0.2	<0.2	--
Tetrachloroethylene	0.2	<0.2	--
Trichloroethylene	0.1	<0.1	--
Vinyl Chloride	0.2	<0.2	--
Background	1	0	0
Fluoride	0.1	0.2	--
Alachlor	0.3	<0.3	--
Aldicarb	3	<3	--
Aldrin + Dieldrin	0.02	<0.02	--
Atrazine + Metabolites	0.5	<0.5	--
Azinphos-methyl	1	<1	--
Bendiocarb	3	<3	--
Benzo(A)pyrene	0.005	<0.005	--
Bromozynil	0.3	<0.3	--
Carbaryl	3	<3	--
Carbofuran	1	<1	--
Chlordane (Total)	0.04	<0.04	--
Chlorpyrifos	0.5	<0.5	--
Cyanazine	0.5	<0.5	--
DDT + Metabolites	0.01	<0.01	--
Diazinon	1	<1	--
Dicamba	5	<5	--
Dichlorophenol 2, 4-	0.1	<0.1	--
Dichlorophenoxy acetic acid 2, 4- (2,4-D)	5	<5	--
Diclofop-methyl	0.5	<0.5	--
Dimethoate	1	<1	--
Dinoseb	0.5	<0.5	--
Diquat	5	<5	--
Diuron	5	<5	--
Glyphosate	25	<25	--

RENFREW COUNTY CATHOLIC DISTRICT SCHOOL BOARD

Parameter	M.D.L.	Pump Room Treated	Kitchen/Staff Room
Heptachlor + Heptachlor Epoxide	0.1	<0.1	--
Lindane (Hexachlorocyclohexane, Gamma)	0.1	<0.1	--
Malathion	5	<5	--
Methozechlor	0.1	<0.1	--
Metolachlor	3	<3	--
Metribuzin	3	<3	--
Paraquat	1	<1	--
Paranthion	3	<3	--
Pentachlorophenol	0.1	<0.1	--
Phorate	0.3	<0.3	--
Picloram	5	<5	--
Poly-Chlorinated Biphenyls (PCB's)	0.05	<0.05	--
Prometryne	0.1	<0.1	--
Simazine	0.5	<0.5	--
Temephos	10	<10	--
Terbufos	0.3	<0.3	--
Tetrachlorophenol, 2, 3, 4, 6-	0.1	<0.1	--
Triallate	10	<10	--
Trichlorophenol 2, 4, 6-	0.1	<0.1	--
Trichlorophenoxy acetic acid 2,4, 5-	10	<10	--
Trifluralin	0.5	<0.5	--

Note: Sampling frequency is once per five years.

MDL – Minimum Detectable Limit (micrograms)